



1. RISER CONDUIT SHALL BE SCHEDULE 40 STEEL. PVC CONDUIT SHALL BE SCH 40 WITH 36" SWEEPS.
2. 2,500 lb. MULETAPE SHALL BE INSTALLED IN CONDUIT STRING OR ROPE IS NOT ACCEPTABLE-
3. MAINTAIN 36" HORIZONTAL CLEARANCE FROM SIDE OF ELECTRICAL EQUIPMENT TO NEAREST GAS FACILITY .

GRICUA UNDERGROUND-SES

